

**CITY OF BEVERLY**  
**ADDENDUM NO. 5, January 22, 2015**

**RE:            INVITATION FOR BID**  
**#14-028 PURCHASE FOUR GLASS DOORS**

**FROM:        David Gelineau**  
**Purchasing Agent**  
**191 Cabot Street**  
**Beverly, MA 01915**

**Please acknowledge receipt via electronic mail, telephone, or facsimile**

**TO:            ALL PROSPECTIVE BIDDERS**

This addendum forms a part of the Invitation for Bids from the City of Beverly for:  
#14-028 Purchase Four Glass Doors

**Question:** Is the 2 ¼” door width critical or can we use a 1 ¾” all fiberglass door as long as it meets the testing requirement?

**Answer:** A 1 ¾” all fiberglass door can be used as long as it meets all of the performance requirements.

Please sign this acknowledgement of receipt of the Addendum No.5 and return with your bid.

---

Signature of Bidder