

CITY OF BEVERLY
ADDENDUM NO. 2, February 4, 2015

RE: INVITATION FOR BID
#14-036 Furnish and Install Poles and Netting at the Beverly High School Athletic Field

FROM: David Gelineau
Purchasing Agent
191 Cabot Street
Beverly, MA 01915

Please acknowledge receipt via electronic mail, telephone, or facsimile, sign and include with your bid submittal.

TO: ALL PROSPECTIVE BIDDERS

This addendum forms a part of the Invitation for Bids from the City of Beverly for:
#14-036 Furnish and Install Poles and Netting at the Beverly High School Athletic Field.

Please delete the following question and answer from Addendum 1- It does not apply to this bid

Question: The Scope of Work lists the operator being compatible with Beverly Fire Department equipment, am I to assume that the integration of the Opticom or Fire eye will be done by City of Beverly?

Answer: *We will assist coordinating in any way we can.*

Question: What is the permissible sag allowed in the guy wire, are there any specs dictating which kind of ground anchors are required, is there a spec for the galvanized pole line hardware?

Answer: *No more than 6 inches per one hundred feet of cable. The guy wire is 5/16 inch extra high strength galvanized guy wire. The bolts are 3/4 inch galvanized and the hardware is 5/8 inch galvanized. Ground anchors should be sufficient to hold Netting but can be of any appropriate design or installation method.*

If you have already submitted your bid please sign and email to:

dgelineau@beverlyma.gov or fax to 978-921-8301 and we will put it with your bid.

Please sign this acknowledgement of receipt of the Addendum No.2 and return with your bid.

Signature of Bidder